

INFORME DE REUNIÓN

Nº22

1. ANTECEDENTES DE LA REUNIÓN

CLIENTE	CATERPILLAR			
PROYECTO	CATERPILLAR OFFICES SANTIAGO, CHILE			
FECHA	Fecha 21-12-12	Inicio 11:30	Termino 12:30	
LUGAR	Oficinas Caterpillar, Ed. Birmann			
TIPO	Caterpillar IT requests			
ASISTENTES				
CONTRACT	1. Claudio Perez 2. Barbara Mac Cawley			
CATERPILLAR	1. Delx Andrade 2. Freddy Pacheco 3. Francisco Muñoz			

2. OBJETIVOS Y TABLA

OBJETIVOS GENERALES	Caterpillar IT request
TEMAS A TRATAR	A.- Visit to Caterpillar Server Rooms al Birmann and El Bosque B.- Requests seen in this visit

3. NOMENCLATURA ESTADO

NUEVO: **N** RESUELTO: **R** PENDIENTE: **P** INFORMATIVO: **I** PERMANENTE: **PER**

4. ACUERDOS Y CONTENIDOS

TEMA	FECHA ORIGINAL	DETALLE	ESTADO	RESPONSABLE	FECHA ENTREGA
A.-Requerimientos IT					
A1	21/12	Link Rack of floor 14 will be of 42 U	I	Caterpillar Delx Andrade	
A2	21/12	Actual UPS Power - Birmann – 8 KVA - El Bosque – 3 KVA	I	Caterpillar Delx Andrade	
A3	21/12	Brand of Data Cabling will be inform. Consider Systimax and as a second one Uniprice.	I	Caterpillar Delx Andrade	

A4	21/12	Consider in th server Room 1 • 2 plugs of Normal Energy • 2 Rj45 (Data)	I	Caterpillar Delx Andrade	
A5	21/12	○ Electric Board of the server room with Energie Multi Meter	I	Caterpillar Delx Andrade	
A6	21/12	○ Consider WiFi as standard use. And put in each spot • 1 plugs of Computer Energy (not magic, chilean plug configuration) • 1 Rj45 (Data)	I	Caterpillar Delx Andrade Carlos Adasme	
A10	21/12	○ Consider points for CAT TV. How many points and what is require. Energy, data, etc.	P	Caterpillar Delx Andrade	
A11	21/12	○ Validate Consider Energy Generator: • Server room • Emergency Lightning • Some work areas that need high availability ○ Validate Consider cabling generator to Server Room	P	Caterpillar Delx Andrade	
B.-Pending information request					
B1	21/12	○ Consider points for CAT TV. How many points and what is require. Energy, data, etc.	P	Caterpillar Delx Andrade	
B2	21/12	○ Validate Consider Energy Generator: • Server room • Emergency Lightning • Some work areas that need high availability ○ Validate Consider cabling generator to Server Room	P	Caterpillar Delx Andrade	
B3	21/12	○ Validate and confirm if we should consider basic domótica for Board room with one sceneary.	P	Caterpillar Delx Andrade Carlos Adasme	21/12
B4	19/12	○ Validate and confirm if we should consider basic domótica for Board room with one sceneary.	P	Caterpillar Delx Andrade Carlos Adasme	21/12

5. PROXIMA REUNIÓN

FECHA	Por definir	Inicio:	Termino:	Duración:
LUGAR				
TIPO				
TABLA				
ASISTENTES				
CONTRACT				
CLIENTE				

NOTA: Esta minuta refleja el entendimiento y conclusiones alcanzadas por los asistentes llevadas a cabo durante la junta arriba citada. Se solicita que en el caso de tener cualquier comentario que difiera de lo expresado lo comuniquen por escrito dentro de las 48 hrs. de recibida la presente, caso contrario se dará por conformada. Se envía copias a todos los presentes en la reunión.